Note:

- 1. Anchor bolts have to be centered on the concrete foundation.
- 2. This is for standard soil conditions. Verify with civil engineer for other types **POLE** of soil conditions. **HANDHOLE BOLT PROJECTION** SHOULD BE 3 ½". **GRADE-**(4) #5 REBAR WITH #2 TIES OR HOOPS. 4'-0" **ANCHOR** BOLTS (¾"Ø x 1'-6") ========== SEE PLAN FOR CIRCUIT. **PVC SCHEDULE 80 ELBOW - SIZE BY**

PEDESTRIAN LIGHTING POLE FOUNDATION



LG-A02 PED LIGHT BASE

CONTRACTOR
CONCRETE BASE

PEDESTRIAN LIGHT POLE FOUNDATION

APPROVED BY: SN APPROVE DATE

DETAIL CODE

LG