



## **GENERAL NOTES:**

- CONCRETE SHALL BE CLASS B.
  CAST-IN-PLACE CONCRETE WALLS SHALL BE FORMED ON BOTH SIDES.
- 3. STEPS SHALL BE PROVIDED WHEN INLET DIMENSION "H" EXCEEDS 3'-6" AND SHALL BE IN ACCORDANCE WITH AASHTO M 199.
- 4. ALL INLETS SHALL BE CONSTRUCTED ON GRADE PER DESIGN PROFILE.







U-D01 1VALY.INLET

WR VALLEY INLET (SINGLE)

**DETAIL** CODE

10/2016

APPROVED BY: SN APPROVE DATE